

HOLMENS BRUK

KRAFTFÖRBRUKNING I BRAVIKEN MW, MVAR, MWH, DAG 351, TIS DAGEN, 1980-12-16, V50

KL	INTAG		MT		SUMMA		TA		TB		TC		TD		TE		TR	
	MW	MVAR	MW	MVAR	MW	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	
14 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
16																		
08	87.6	10.8	4.5	4.0	92.1	10.3	2.9	12.4	-5.6	21.2	7.8	23.9	0.3	11.8	2.9	0.1	0.2	
18 09	87.6	10.8	4.4	4.3	92.0	9.5	3.2	11.8	-5.5	21.3	7.8	24.2	0.4	11.2	3.0	0.1	0.2	
10	87.6	10.8	4.3	5.1	91.9	9.6	3.2	12.0	-5.7	21.4	7.7	24.1	0.4	11.1	2.6	0.1	0.2	
20 11	87.6	10.8	4.6	5.2	92.2	9.5	3.2	13.1	-4.6	21.2	7.9	22.3	-0.1	11.3	1.8	0.1	0.2	
12	87.6	10.8	4.8	5.1	92.4	6.2	3.5	15.9	-3.4	21.2	8.0	19.3	-2.0	11.7	1.8	0.1	0.2	
22 13	87.6	10.8	4.3	4.5	91.9	2.1	3.8	16.1	-3.6	21.4	8.1	19.1	-2.2	11.4	2.0	0.1	0.2	
14	87.6	10.8	4.9	4.6	92.5	2.1	3.7	16.1	-3.6	21.3	8.0	19.4	-2.0	10.9	1.8	0.1	0.2	
24 15	87.6	10.8	4.6	4.5	92.2	3.9	3.4	16.2	-3.4	21.4	8.0	19.5	-1.9	10.9	1.7	0.1	0.2	
16	87.6	10.8	5.2	3.9	92.8	11.1	3.4	16.4	-2.9	21.3	7.9	19.6	-1.7	11.1	3.0	0.1	0.2	
26 17	87.6	10.8	5.0	4.2	92.6	11.2	3.5	16.5	-2.8	21.4	7.9	20.3	-1.3	10.8	2.2	0.1	0.2	
18	87.6	10.8	5.1	5.0	92.7	10.4	3.2	16.3	-2.9	21.0	7.6	20.3	-1.2	11.1	1.7	0.1	0.2	
28 19	87.6	10.8	4.9	4.0	92.5	11.0	3.6	16.6	-2.8	20.9	7.6	19.9	-1.4	11.4	2.4	0.1	0.2	
20	87.6	10.8	4.6	4.3	92.2	9.9	3.2	16.5	-2.8	21.0	7.5	19.5	-1.7	11.5	2.3	0.1	0.2	
30 21	87.6	10.8	4.5	4.0	92.1	10.5	3.6	16.6	-2.8	21.3	7.7	19.6	-1.6	11.4	2.6	0.1	0.2	
22	87.6	10.8	4.5	4.7	92.1	10.1	3.5	16.6	-2.9	21.4	7.6	19.7	-1.6	10.7	2.5	0.1	0.2	
32 23	87.6	10.8	4.7	4.0	92.3	13.9	1.8	16.9	-2.6	21.4	7.9	19.6	-1.7	11.2	2.9	0.1	0.2	
24	87.6	10.8	4.8	3.1	92.4	16.6	0.6	16.7	-2.8	21.2	7.9	19.4	-1.8	11.7	4.1	0.1	0.2	
34 01	87.6	10.8	5.1	2.8	92.7	15.7	0.3	16.4	-3.0	21.4	8.0	19.5	-1.8	11.1	4.2	0.1	0.2	
02	87.6	10.8	5.0	2.8	92.6	15.6	0.3	16.6	-3.0	21.5	8.0	19.5	-1.8	11.2	4.2	0.1	0.2	
36 03	87.6	10.8	5.2	2.8	92.8	15.5	0.4	16.4	-3.1	21.4	7.9	19.6	-1.8	11.1	4.2	0.1	0.2	
04	87.6	10.8	5.1	2.7	92.7	15.3	0.2	16.2	-3.2	21.5	8.0	19.6	-1.8	11.2	4.4	0.1	0.2	
38 05	87.6	10.8	5.1	2.6	92.7	15.2	0.2	15.4	-3.2	21.3	7.9	19.4	-1.9	11.4	4.5	0.1	0.2	
06	87.6	10.8	4.7	2.5	92.3	15.2	0.2	16.2	-3.2	21.5	8.0	19.3	-2.0	11.2	4.5	0.1	0.2	
40 07	87.6	10.8	4.4	3.9	92.0	15.6	0.4	16.6	-2.4	21.6	8.0	19.1	-1.8	12.0	3.1	0.1	0.2	
42 SA																		
MWH	2102.4	259.2	114.2	94.5	2216.6	266.0	55.4	376.6	-82.0	511.4	188.8	485.6	-33.8	270.3	70.3	2.7	4.3	
44 MVARH	1912.6		1912.6															
46 MAX	189.8																	
MW,	87.6	10.8	5.2	5.2	92.8	16.6	3.8	16.9	0.0	21.6	8.1	24.2	0.4	12.0	4.5	0.1	0.2	
48 MVAR																		

2026.8 - 2028.9 = 2.1 = 0.1%

1912.6